

MONTAGEANLEITUNG


Technische Daten TS 99 FLR-K

Eingang:	230 V AC +10%/-15%
	120 mA/28 VA / 50 Hz
Ausgang:	24 V DC /460 mA / 11 W
Schutzart:	IP 30
Schutzklasse:	II
Rauchscharter:	24 V DC/50 mA
Temperatur:	-20°C/+60°C


Technische Daten EMF


Betriebsspannung:	24 V DC
Leistungsaufnahme:	2 W
Einschaltdauer:	100 % ED



- **Arbeiten an Elektroanlagen dürfen nur von geschulten Fachkräften ausgeführt werden.**
- **Überprüfen, ob die bauseitige Stromzuführung (230 VAC) spannungslos geschaltet ist.**
- **Im Versorgungskreis muss ein Sicherungsautomat 10A/B vorhanden sein. Dieser dient gleichzeitig als Trennvorrichtung, um den FLR-K spannungsfrei zu schalten.**
- **Zur Zugentlastung muss die Netzzuleitung vor dem FLR-K ausreichend befestigt werden.**
- **Der Querschnitt der Netzzuleitung (NYM) darf max. 1,5 mm² betragen. Der Schutzleiter wird nicht elektrisch verwendet. Die Klemme (PE) ist aber bei vorhandenem Schutzleiter zu verwenden.**
- **Brandmelder von Feststellanlagen dürfen keine weiteren Alarmierungseinrichtungen (z.B. Übertragungseinrichtungen für Brandmeldungen) ansteuern.** 
- **Wird als Option das Alarmmodul verwendet, ist das Verbindungskabel zum Rauchscharter über die Messkammer zu führen um die Raucheindringung nicht zu behindern.**
- **Nach den Richtlinien für Feststellanlagen des Instituts für Bautechnik, Berlin, muss jede Feststellvorrichtung auch von Hand ausgelöst werden können. Werden Freilauftürschließer verwendet, muss die Auslösung über einen Taster erfolgen. Der hierfür verwendete Handauslösetaster muss rot sein und die Aufschrift "Tür schließen" tragen. Der Taster muss sich in unmittelbarer Nähe des Abschlusses befinden und darf durch den festgestellten Abschluss nicht verdeckt sein.**

- ① Rauchmeldezentrale
- ② Elektromagnetische Feststellvorrichtung
- ③ Rauchmelder
- ④ DORMA HT - Handauslösetaster für Feststellvorrichtungen.

a Montage der Festellanlage FLR-K wenn die Unterflache der Decke auf einer oder auf beiden Seiten der Tür weniger als 1 m über der Sturzunterkante liegt. ¹⁾
Entsprechende Anschlußpläne siehe separates Blatt.

b Ist die Unterflache der Decke auf einer oder auf beiden Seiten der Tür mehr als 1 m über der Sturzunterkante, sind zusätzlich zum Sturzmelder (FLR-K) zwei Deckenmelder anzubringen. ¹⁾
Entsprechende Anschlußpläne siehe separates Blatt

- 1** Befestigungspunkte für Schließer und Gleitschiene nach Schablone TS 99 FLR-K oder nach Maßbild bohren.
- 2**
- 3** Für bauseitige Stromzuführung 230 V AC Ø 12 und für die Verbindung zum TS 99 FL, Handtaster und evtl. benötigten Deckenmeldern Ø 10 mm bohren und Kabel legen.

4 Verteilerdose anschrauben.

5 Montageplatte anschrauben.

6 Schließer auf die Montageplatte schrauben.



Darauf achten, daß das Kabel in der Nut der Montageplatte liegt und nicht beschädigt wird.

7 In der Verteilerdose die Kabel der Spannungs-
zuführung 24 V DC anklennen ①.
Verbindungskabel aufstecken ②.
Internes Verbindungskabel mit dem Stecker der
elektrohydraulischen Feststellung verbinden ③.

8 Hebel ca. 10° zum Türblatt aufsetzen und festschrauben.

9a DIN-L
FLR-K Einheit anschrauben.

9b DIN-R
Gleitschiene um 180° drehen ①②③.
FLR-K Einheit anschrauben.

10 Ventil zur Regulierung der Schließgeschwindigkeit
schließen ① und Tür ca. 45° öffnen ②.

11 Hebel in Richtung Gleitschiene drücken ① und mit
Gleitstück verbinden ②.

12 Schließkraft einstellen.

13 Schließgeschwindigkeit 180°- 0° einstellen ①.
Endschlag 7°- 0° einstellen ②.


14 Endkappen aufstecken ①.
Achsausnehmung ausbrechen ② und Verkleidung
aufklipsen ③.



Darauf achten, daß die Kabel nicht beschädigt werden.
DORMA Logo aufklipsen ④.


¹⁾ Richtlinien für Feststellanlagen des
Deutschen Instituts für Bautechnik, Berlin

15 Klemmenbelegung FLR-K



- 16** Handtaster anschließen und eventuell vorhandene Deckenmelder anschließen - siehe Anschlusspläne. **Abschlusswiderstände beachten!**

RS-Alarmmodul (Option) einsetzen und anklemmen. Das Alarmmodul kann nicht verwendet werden, wenn die Relaiskontakte 7,8,9 bereits belegt sind.

Um die Schutzklasse II  (Schutzisolierung) einzuhalten, ist die 230 V Zuleitung doppelt isoliert bis zur Anschlussklemme zu verlegen.

Kabel abisolieren.

Kabel für die Stromzuführung anklemmen ①.

Berührungsschutz schließen ② und zuschrauben ③.

17 Reset (Wiederscharfschaltung)

Betriebsanzeige blinkt grün, sobald kein Rauch bzw. Prüfgas mehr in der Rauchkammer ist.

Die Wiederscharfschaltung erfolgt über den Reset Taster.

Beiliegendes „RESET“ Etikett auf die Verkleidung kleben.

- 18** Rote Schutzhaube von der Rauchmeldeeinheit entfernen ①.

Spannung anlegen - Betriebsanzeige blinkt grün ②.

Reset Taster drücken ③ - Betriebsanzeige leuchtet grün.

19 Freilauffunktion einstellen

Schalter der Verteilerdose auf "EIN" stellen (24V DC für Feststellvorrichtung) ①.

Türflügel auf die gewünschte Feststellposition öffnen ②. Die Schließachse wird in dieser Position über die elektrohydraulische Feststellvorrichtung gehalten, die Tür kann jedoch über die Freilauffunktion im Hebel frei bewegt werden. Tür offen stehen lassen.

20 Funktionsprüfung Handtaster

Stromzufuhr über Handtaster (z.B. DORMA HT) unterbrechen ①. Die Feststellvorrichtung wird stromlos geschaltet und die Tür wird geschlossen ②. Betriebsanzeige blinkt grün. Die Wiederscharfschaltung erfolgt über den Reset Taster ③. Betriebsanzeige leuchtet grün.

- 21** Endkappenblenden aufclippen ①.

Markierte Aussparung an der Verkleidung ausbrechen ②. Verkleidungen aufclippen ③.

22 Funktionsprüfung



Anwendungs- und Sicherheitshinweise auf dem Prüfgas und Sicherheitsdatenblatt beachten.

Türflügel öffnen ①.

Prüfgas (Hekatron 918/5) aus ca. 10-15 cm

Entfernung in Richtung Rauchkammer sprühen ②.

Nach ca. 4-6 kurzen Sprühstößen schaltet die Betriebsanzeige auf Alarm (rot) um. Ist der FLR-K mit dem RS-Alarmmodul (Option) ausgestattet wird der Alarm auch akustisch angezeigt.

Die Feststellvorrichtung wird stromlos geschaltet und die Tür wird geschlossen ③.

Betriebsanzeige blinkt grün, sobald kein Rauch bzw. Prüfgas mehr in der Rauchkammer ist.



Die Wiederscharfschaltung erfolgt über den Reset Taster ④. Betriebsanzeige leuchtet grün.

- 23** Mitgelieferte Staubschutzhaube aufstecken, damit während weiterer Rohbauarbeiten kein Staub in den Rauchmelder gelangt.




Vor der endgültigen Inbetriebnahme ist die Staubschutzhaube zu entfernen und eine weitere Funktionsprüfung gemäß Punkt 22 durchzuführen.

24 Funktionen der LED's

LED an  LED aus 

Betriebsanzeige LED 1 (grün/rot)

Betrieb: grün 


Alarm: rot 


Handreset erforderlich: blinkt grün 

(siehe auch Punkt 17)


Wartungsanzeige LED 2 (gelb)

Fällige Wartung: blinkt 

Verschmutzung: blinkt 

Störung: Dauer 

ABNAHMEPRÜFUNG UND WARTUNG

 Merkblatt über die Verwendung von Feststellanlagen.



Wird der Sturzmelder FLR-K in Räumen mit großem Staubanfall eingesetzt, sind die vorgeschriebenen Wartungsintervalle unbedingt einzuhalten, oder ggf. sogar zu verkürzen, da Staubablagerungen im Melder zu Fehlauslösungen führen können.



EN 14600 Anhang C

WEITERE HINWEISE / VORSCHRIFTEN



Zulassungsbescheid



Merkblatt über die Verwendung von Feststellanlagen.



Richtlinien für Feststellanlagen des Deutschen Instituts für Bautechnik, Berlin.

FIXING INSTRUCTIONS

Technical Data TS 99 FLR-K

Input:	230 V AC +10%/-15%
	120 mA/28 VA / 50 Hz
Output:	24 V DC /460 mA / 11 W
Type of Protection:	IP 30
Protection class:	II
Smoke switch:	24 V DC/50 mA
Temperature:	-20°C/+60°C


Technical Data, Hold-open Device (EMF)


Operating voltage:	24 V DC
Power input:	2 W
Duty factor:	100 % continuous duty



- **Work on electrical equipment and systems may only be performed by properly trained specialist personnel.**
- **Check to ensure that the line power supply (230V AC) has been disconnected and is no longer live.**
- **IA 10 A/B miniature circuit breaker must be provided in the supply circuit. This can also be used as the isolator for disconnecting the FLR-K and making it dead.**
- **The power cable leading to the FLR-K must be properly secured to ensure effective strain relief.**
- **The power cable (NYM) conductor cross section should be not greater than max. 1.5 mm². The PE conductor is not electrically utilised. The terminal (PE) should, however, be used where a PE conductor is provided.**
- **Fire/smoke detectors controlling hold-open systems must not be used to actuate any further alarm devices (e.g. fire alarm transmission systems).**¹⁾
- **If the optional alarm module is installed, the cable connecting it to the smoke switch must be led over and across the measurement chamber in order to ensure that smoke penetration is in no way hindered.**
- **According to the guidelines for hold-open systems issued by the Institute of Building Technology, Berlin, it must be possible to release every hold-open device by manual means. If free-swing door closers are used, release must be initiated by a manual pushbutton. The manual release pushbutton used for this must be red and carry the inscription "Close Door". The pushbutton must be in the immediate vicinity of the door (barrier) and must not be concealed when the door (barrier) is open.**

- ① Integral lintel-mounted smoke detector.
 ② Electro-magnetic hold-open device.
 ③ Ceiling-mounted smoke detector.
 ④ DORMA HT manual release pushbutton for hold-open devices.

a Installation arrangement of the FLR-K for applications where the bottom surface of the ceiling is less than 1m above the bottom edge of the lintel on one or both sides of the door. ¹⁾
 See separate sheet for associated connection diagrams.

b If the bottom surface of the ceiling is more than 1m above the bottom edge of the lintel on one or both sides of the door, two ceiling-mounted smoke detectors must be installed in addition to the lintel-mounted detector (FLR-K) ¹⁾
 See separate sheet for associated connection diagrams.

- 1 Drill fixing points for closer and slide channel using TS 99 FLR-K template or as per dimensioned drawing.
- 2
- 3 Drill holes of 12 mm dia. for the 230V AC power cable (by others) and of 10 mm for connection to the TS 99 FL, manual pushbutton and any required ceiling-mounted detectors. Install cabling.

4 Fix junction box.

5 Fix mounting backplate.

6 Fix closer to the mounting backplate.



Ensure that the cable is located in the mounting backplate groove and that it remains undamaged.

7 Connect 24V DC supply cable to the junction box terminal ①.
 Connect interconnecting cable ②.
 Connect the internal cable to the connector of the electro-hydraulic hold-open device ③.

8 Fit arm at an angle of approx. 10° from the door leaf and tighten fixing screw

9a LH (ISO 6) handing:
 Fix FLR-K unit.

9b RH (ISO 5) handing:
 Rotate slide channel 180° ①②③.
 Fix FLR-K unit.

10 Close valve for adjusting closing speed ①, and open door approx. 45° ②.

11 Push arm towards slide channel ① and connect to slide block ②.

12 Adjust spring strength (closing force).

13 Adjust closing speed 180° - 0° ①.
 Adjust latching action 7° - 0° ②.

14 Fit end caps ①.
 Break out spindle recess tab ② and fit clip-on cover ③.




Ensure that the cables are not damaged in this process.

Clip on DORMA logo badge ④.

¹⁾ Guidelines for hold-open systems issued by the Institute for Building Technology, Berlin. In countries outside Germany, consult local regulations.

15 Terminal assignment FLR-K




²⁾ See connection diagrams

- 16** Connect manual pushbutton and any required ceiling-mounted detectors – see connection diagrams.



Terminal resistors must be properly installed!

Insert and connect RS smoke alarm module (option). The alarm module cannot be used if relay contacts 7, 8 and 9 are already in use.

In order to comply with protection class II  (total insulation), the 230V power cable should be installed with double insulation up to the connection terminal. Remove cable insulation at the end. Connect power cable to terminals ①. Close the shock hazard protection cover ② and screw down ③.

17 Reset

Status display flashes green as soon as there is no longer any smoke or test gas in the smoke chamber. Reset is performed by pressing the reset pushbutton. Attach the enclosed RESET label.

- 18** Remove the red protective cap from the smoke detector unit.

Switch on power supply – status display flashes green ②. Press the RESET pushbutton ③ – status display should show green.

19 Setting the free-swing function

Set the switch in the junction box to “ON” (24V DC for hold-open device) ①. Open the door leaf to the required hold-open position ②. The closer spindle is held in this position by the electro-hydraulic hold-open device, but the door can be freely moved thanks to the free-swing arm assembly. Leave the door open.

20 Functional test of manual pushbutton

Interrupt power supply using manual pushbutton (e.g. DORMA HT) ①. The hold-open device is de-energised and the door is closed ②. Status display flashes green. Press the RESET pushbutton ③. – status display should show green.

Clip on end caps ①.
Break out the tab as marked for the recess in the cover ②.
Clip on cover ③.

22 Functional checks



Ensure compliance with the instructions for use and also the safety instructions provided on the test gas container and safety datasheet.

Open door leaf ①.
Spray test gas (Hekatron 918/5) from a distance of approx. 10-15cm towards the smoke chamber ②. After approx. 4-6 short bursts, the status display should switch to alarm (red). If the FLR-K is equipped with the RS smoke alarm module (option), an audible alarm is also sounded. The hold-open device is tripped and released, and the door closes ③. Status display flashes green as soon as there is no longer any smoke or test gas in the smoke chamber. Reset is performed by pressing the RESET pushbutton ④. Status display should show green.

- 23** Fit dust protection cover supplied so that dust is prevented from entering the smoke detector during any subsequent building or finishing work.






Prior to final commissioning, remove the dust protection cover and perform a further function check in accordance with step 22.




24 Function of the LEDs

LED on  LED off 


Status display LED 1 (green/red)

Standby: green 
Alarm: red 
Manual reset necessary: green flashing 
(see also item 17)

Service display LED 2 (yellow)

Servicing due: flashes 
Contamination: flashes 
Fault: continuous 

FINAL INSPECTION AND MAINTENANCE


 Instruction sheet relating to the use and application of hold-open systems.³⁾





If the FLR-K lintel-mounted smoke detector is used in rooms with a high dust content, ensure compliance with the specified maintenance intervals. These may even have to be reduced in order to ensure that dust deposits in the detector do not give rise to nuisance tripping.

 EN 14600 Appendix C

FURTHER INFORMATION / REGULATIONS

 Approval certificate

 Instruction sheet relating to the use and application of hold-open systems.³⁾

 Guidelines for hold-open systems published by the Institute for Building Technology, Berlin ³⁾, or equivalent national guidelines

³⁾ These documents are only printed in German as they refer exclusively to the German market.