



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

CLASSIFICATION REPORT NO. 2021-27-0837-K1

Version 1.en

This test certificate only certifies the specifications of the tested product and does not prejudge the specifications of similar products. The test performed in accordance with - EN 1026 : 2016-09 “Windows and doors –Air permeability –Test method”

Applicant Dormakaba Kapı ve Güvenlik Sistemleri San. Tic. A.Ş.
Merkez Mah. Bağlar Cad. B Blok No:14B İç Kapı No:30
Kağıthane - İstanbul

Product type One leaf power operated sliding hermetic door

Product name ES 200 iCat Hermetic Door


Sealing EPDM

Dimension Leaf dimensions (W x H) max. 1452 mm x 2246 mm

Classification According to test report No. 2021-27-0837-B1 from July 07, 2022:



EN 1026 Air Permeability EN 12207 Class 4



Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016

Nedret Sürmeli
Head of Test Laboratory Branch
Office PFB Turkey
PFB Prüfzentrum für
Bauelemente Yapı Elemanları
Test Merkezi San. Ve Tic. Ltd.
Şti.



Stephanskirchen
July 07, 2022

Yiğit Altuğ
Responsible Official