

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance

0432-CPR-00026-80

Version 01

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Door coordinators SR 390 and SR 392

Door coordinators for double-leaf swing doors as detailed and classified in annex 1,

placed on the market under the name or trade mark of

dormakaba Deutschland GmbH

DORMA Platz 1
58256 Ennepetal, Germany

and produced in the manufacturing plant(s)

DO 2.1

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 1158:1997/A1:2002/AC:2006

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 15.01.2020 and will remain valid until 15.01.2025 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 15.01.2020



By order

Dipl.-Ing. Friedrich
Head of Certification Body

This Certificate consists of 1 page and 1 annex(es).

The original of this document was issued in German language.
In case of doubt only the German version is valid.



List of Products

Type :	Door coordinator SR 390
Description :	Door coordinator for double-leaf swing doors
Installation :	Frame fixing, pull side according to manufacturer specification
Size :	3 - 7
Classification :	3 8 3-7 1 1 3
Manufacturing plant :	DO 2.1
Remarks :	The carry bar „MK 396“, „MK 397“ and „MK 397 V“ are always required if the correct closing sequence of both door leaves is not achieved.

Intended use:

For single- and double leaf fire- and/or smoke protection doors

<i>Essential properties</i>	<i>Clauses with requirements in EN 1158:1997/A1:2002/AC:2006</i>	<i>Performance of the product</i>
<i>Self-closing</i>	5.1.2 <i>Completeness of the products</i> 5.1.3 <i>Correct closing sequence</i> 5.2.1 <i>General</i> 5.2.2 <i>Overload behaviour in closing direction</i> 5.2.3 <i>Manipulation</i> 5.2.4 <i>Resistance in waiting position</i> 5.2.6 <i>Damage</i> 5.2.8 <i>Use on fire-/ smoke protection doors</i>	<i>passed</i> <i>passed (Size 3-7)</i> <i>passed (Size 3-7)</i> <i>passed (Size 3-7)</i> <i>passed (Size 3-7)</i> <i>passed (Size 3-7)</i> <i>passed (Class 1)</i>
<i>Durability</i> <i>Self-closing</i>	5.2.5 <i>Durability</i> 5.2.7 <i>Corrosion resistance</i> 5.2.7.1 5.2.7.2 5.2.7.3	<i>Class 8 (500.000 Cycles): passed</i> <i>Class 3 (96h): passed</i> <i>Class 3 (96h): passed</i> <i>Class 3 (96h): passed</i>
<i>Dangerous substances</i>	<i>Annex ZA.3</i>	<i>The manufacturer has not declared any dangerous substances.</i>

Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

Type :	Door coordinator SR 392
Description :	Door coordinator for double-leaf swing doors
Installation :	Frame fixing, push side on door lintel according to manufacturer specification
Size :	3 - 7
Classification :	3 8 3-7 1 1 3
Manufacturing plant :	DO 2.1
Remarks :	Size 1: Length 1050mm for door widths >800mm Size 2: Length 650mm for door widths <800mm The carry bar „MK 396“, „MK 397“ and „MK 397 V“ are always required if the correct closing sequence of both door leaves is not achieved.

Intended use:

For single- and double leaf fire- and/or smoke protection doors

Essential properties	Clauses with requirements in EN 1158:1997/A1:2002/AC:2006	Performance of the product
Self-closing	5.1.2 Completeness of the products	passed
	5.1.3 Correct closing sequence	passed (Size 3-7)
	5.2.1 General	
	5.2.2 Overload behaviour in closing direction	passed (Size 3-7)
	5.2.3 Manipulation	passed (Size 3-7)
	5.2.4 Resistance in waiting position	passed (Size 3-7)
Durability Self-closing	5.2.6 Damage	passed (Size 3-7)
	5.2.8 Use on fire-/ smoke protection doors	passed (Class 1)
	5.2.5 Durability	Class 8 (500.000 Cycles): passed
	5.2.7 Corrosion resistance	
	5.2.7.1	Class 3 (96h): passed
	5.2.7.2	Class 3 (96h): passed
	5.2.7.3	Class 3 (96h): passed
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.