

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7796

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Dorma 9600 Touchbar Range Panic Exit devices

Intended use: For use on single leaf escape panic doors, & Locked doors on escape routes.

Essential characteristics	Performance	Designated technical specification
Mechanical Test Evidence: WIL 305297 / WIL 364399 & WIL 506200		
Fire Test Evidence: N/a		
Clause 4.2.1 Ability to release (for doors on panic routes) Release function Panic exit device mounting Exposed edges and corners Double doorset Single doorset Bar installation Bar length Bar projection Bar end Operating bar face Test rod Door face gap Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass > 0,5 mm Pass Pass Pass Z < 150 mm > 60% W < 100mm Pass > 18 mm Pass N/A Pass Pass Pass Pass Pass Door mass ≤ 200 kg, door height ≤ 2500 mm, door width ≤ 1220 mm (Width for FL versions Only) Pass < 80 N with the door unloaded, and < 220 N with the door loaded with 1 000 N Grade 2	BS EN 1125:2008

Certificate of Constancy of Performance

1121-CPR-UK-AAA7796

<p>Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on panic routes) Corrosion resistance Temperature range</p> <p>Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance -Horizontal bar Abuse resistance -Vertical rod Final examination</p>	<p>Grade 3 : 96 h Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° NPD Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 1 000N NPD < 80N with the door unloaded, and < 220N with the door loaded with 1 000N</p>	<p>BS EN 1125:2008</p>
<p>Clause 4.2.1 Self closing ability C (for fire/smoke doors on panic routes) Re-engagement force</p>	<p>< 50N</p>	
<p>Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on panic routes) Durability Re-engagement force</p>	<p>Grade 7: 200 000 cycles < 50N</p>	
<p>Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on panic routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies -</p> <p>Additional requirements</p>	<p>Grade 0: Not suitable for use on fire/smoke door assemblies. -</p>	
<p>Clause 4.1.25 Control of Dangerous substances</p>	<p>If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the Device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.</p>	

Certificate of Constancy of Performance

1121-CPR-UK-AAA7796

Part Number	Description	Single door	Double door	Fire door
9600	Concealed Vertical Rod Exit Device Touch bar	√	√	---
9600FL	Concealed Vertical Rod Exit Device Touch bar Full Length	√	√	---
418	Top Keeper Plate	√	√	---
439	Bottom Keeper Plate	√	√	---
Accessories				
#80R20SC	Cylinder with tail piece	√	√	---
#90X13SC118	Mortise cylinder	√	√	---
OP02	Pull handle	√	√	---
ZODT	Outside box cover	√	√	---
ZP25	Pull Handle outside access device	√	√	---
ZP02	Pull Handle outside access device	√	√	---
ZP03/04	Pull Handle outside access device	√	√	---
ZP11 / ZP12	Pull Handle outside access device	√	√	---
ZK23	Knob operated outside access device	√	√	---
ZK08 / 09	Knob operated outside access device	√	√	---
ZR23	Lever Handle outside access device	√	√	---
ZC23	Lever Handle outside access device	√	√	---
ZT23	Lever Handle outside access device	√	√	---
ZG23	Lever Handle outside access device	√	√	---
ZR08 / 09	Lever Handle outside access device	√	√	---
ZC08 / 09	Lever Handle outside access device	√	√	---
ZT08 / 09	Lever Handle outside access device	√	√	---
ZG08 / 09	Lever Handle outside access device	√	√	---

Certificate of Constancy of Performance

1121-CPR-UK-AAA7796

Placed on the market under the name of

**Dormakaba Deutschland GmbH
DORMA Platz 1
58256
Ennepetal
Germany**

and produced in the manufacturing plant

B/004

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

BS EN 1125 : 2008

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **17/11/2022** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **16/11/2025**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK**