

DOP_0051_UKCA

- Unique identification code of the product-type: Controlled door closing devices **ITS 96 EN 2-4**
- Intended use/es: On fire and smoke compartmentation doors to fulfil the self closing requirements of such doors.
- Manufacturer: dormakaba Deutschland GmbH - DORMA Platz 1 - 58256 Ennepetal
- System/s of assessment and verification of constancy of performance (AVCP): System 1
- Designated standard/s: EN 1154: 1996/A1: 2002/AC: 2006
- UK Approved body/ies: Warringtonfire Testing and Certification Limited 1121
- Declared performance/s:

Essential characteristic	Performance	Harmonised technical specification
Self-closing	<ul style="list-style-type: none"> ▪ Closing doors from $\geq 105^\circ$ open grade 3 ▪ Door closer power size EN 2-4 ▪ Suitability for fire/smoke door use grade1 ▪ Safety grade 1 ▪ Temperature dependence $+40^\circ\text{C}$ and -15°C: $\geq 3\text{s}$ $\leq 25\text{s}$ ▪ Latch control ▪ Adjustable closing force 	EN 1154: 1996/A1: 2002/AC: 2006
Durability of self-closing	<ul style="list-style-type: none"> ▪ Durability 500000 cycles grade 8 ▪ Very high corrosion resistance grade 4 	
Dangerous substances	<ul style="list-style-type: none"> ▪ Substances of very high concern $<$ threshold values 	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Ennepetal 17.03.2023



Michael Hensel

Senior Vice President Market Germany