

### **CERTIFICATE OF APPROVAL** No CF 844

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products The undermentioned products of

### DORMA UK LIMITED

Wilbury Way, Hitchin, Hertfordshire SG4 0AB Fax: 01462 477601 Tel: 01462 477600

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

**CERTIFIED PRODUCT** DORMA ED100 and ED250 **OVERHEAD DOOR OPERATORS** 

TECHNICAL SCHEDULE **TS 34 The Contribution Of Controlled Door Closing Devices And Accessories To Fire Resisting Doorsets** 

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan

**Certification Manager** 

Issued: Reissued: 28<sup>th</sup> March 2011 24<sup>th</sup> March 2021 23<sup>rd</sup> March 2026

Valid to:



Page 1 of 6





#### DORMA ED100 and ED250 OVERHEAD DOOR OPERATORS

1. DORMA surface mounted overhead door operators providing a door closing function, all units have adjustable power:

	Link-arms			Slide arms			
	Projecting arm (Fig. 1) Body door mounted on pull face	Projecting arm (Fig. 61) Body transom mounted on push face	Parallel arm (Fig. 6) Body door mounted on push face	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
ED100	×	✓	*	*	✓	*	✓
ED250	*	✓	*	*	✓	*	✓

**Key:** ✓ - approved **x** - Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

2. This approval relates to their use with the following door assemblies:-

fol agg-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT).

Latched and unlatched, door assemblies consisting of predominantly steel leaves in steel frames, <u>fully-insulated</u> for the required classification period (as defined by BS EN 1634-1:2014+A1:2018 or BS 476: Part 22: 1987), with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM)

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in <u>fully-insulated</u> steel frames having a fire resistance up to 120 minutes (Code ITM)

Latched and unlatched, door assemblies consisting of predominantly steel leaves in steel frames, <u>uninsulated</u> for the required classification period (as defined by BS EN 1634-1:2014+A1:2018 or BS 476: Part 22: 1987), with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM) <u>with closers fitted to the fire risk face only\*</u>

\*The closer <u>must not be used</u> in this application where a specific direction of fire exposure for the doorset cannot be identified

Page 2 of 6 Signed C/014



#### DORMA ED100 and ED250 OVERHEAD DOOR OPERATORS

- 3. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 4. The units are approved on the basis of:
  - i) Initial type testing to the requirements of EN 1154, DIN 18263-4 and BS EN 1634-1:2014+A1:2018
  - ii) An appraisal against TS34
  - iii) Certification of quality management systems
  - iv) Inspection and surveillance of factory production control
  - v) On-going audit testing in accordance with the requirements of EN 1154
- 5. EN1634-1 was issued originally in 2000, with amended versions issued in 2008, 2014 and 2018. The differences between each version are mainly procedural and are not considered to have a practical impact on the performance of the samples under test. On this basis this evaluation is consider applicable to all versions of EN1634-1 issued prior to the issue of this assessment.
- 6. This approval is applicable only to the specified products used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in EN 1154).
- 7. The door operators shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
- 8. Where the door operators are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic- based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
- 9. Timber based doorset shall be installed in accordance with BS 8214.
- 10. The approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Page 3 of 6 Signed C/014



#### **DORMA ED100 and ED250 OVERHEAD DOOR OPERATORS**

11. The following table show acceptable doorsets types and fire resistance periods for the door operators:

	Approved Door Type					
Class	IMM	ММ	ITT	ITM	ITC	
FD20	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
FD30	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
FD60	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
FD120	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
FD240	<b>√</b> *	<b>√</b> *	*	*	×	
E 20	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
EI 20	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
E 30	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
EI 30	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
E 60	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
EI 60	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
E 90	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
EI 90	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
E 120	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
EI 120	<b>√</b> *	<b>√</b> *	✓	<b>√</b> *	×	
E 240	<b>√</b> *	<b>√</b> *	*	*	×	
EI 240	<b>√</b> *	<b>√</b> *	*	*	×	

#### Kev:

approved

Not approved

 ✓\* - <u>IMPORTANT</u> - See Section 2 for limitations on application and scope for steel doors and or frames

Page 4 of 6 Signed C/014

Pol Ryg-



#### DORMA ED100 and ED250 OVERHEAD DOOR OPERATORS

12. Doors are classified as the following types:

**Code ITT** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in timber-based frames.

**Code ITM** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in steel frames

**Code ITC** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

**Code MM** - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

**Code IMM** - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals

#### **Scope of Approval:**

- Doors may not include uninsulated glass above 20% of their total area. Uninsulated glass shall not be included directly beneath the door closer body
- The door operators may not be fitted to doorsets incorporating timber leaves without leaf/frame edge intumescent protection.
- Mechanical Hold open option is not approved.
- <u>IMPORTANT</u> See Section 2 for limitations on application and scope for the use of the door operators with steel doors and/or frames
- Operators are approved for use on both sides of fully insulated steel-based doors
- Operators are approved for use on uninsulated steel-based doors and frames on the fire risk face only. The operator must not be used in this application where a specific direction of fire exposure for the doorset cannot be identified

Page 5 of 6 Signed C/014

Pol Agg-



#### **DORMA ED100 and ED250 OVERHEAD DOOR OPERATORS**

#### **Classification codes**

The above approval provides the following classifications:

DORMA ED100 in Figure 61 or frame mounted body with slide channel applications only:

3	8	4 3	1	1	0
---	---	--------	---	---	---

DORMA ED250 in Figure 61 or frame mounted body with slide channel applications only:

3 8	6 4	1	1	0
-----	-----	---	---	---

#### **Further Information**

Further information regarding the details contained in this data sheet may be obtained from DORMA UK Limited (Tel: 01462 477600).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 6 of 6 Signed C/014

Pol Ragy-