

A vertical black bar on the left side of the page, containing two white squares. The top square is positioned above the "Product Certificate" header, and the second square is positioned above the "Junior Office hinge with steel ball bearing" header.

## Product Certificate

**DORMA-Glas GmbH**  
herewith certifies  
that the product

### Junior Office hinge with steel ball bearing

Art.-Nr. 11.234

was tested according to the EN1935:2002 regarding durability  
and according to the EN1670:2007 regarding corrosion  
resistance with the following results:

Maximum door weight:	<b>60kg</b>
Durability:	<b>Level 7</b> , EN1935:2002 200.000 operations
Corrosion resistance:	<b>Level 3</b> , EN1670:2007

Bad Salzufen, 14.01.08

Dipl.-Ing.  
**Thomas Vogler**  
Division Glas  
Head of Mechanical Design and Development

DORMA-Glas GmbH  
Max-Planck-Str. 33-45  
D-32107 Bad Salzufen