

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance**0432-CPR-00026-90**

Version 02

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Overhead door closer surface mounted TS 98 XEA

Controlled door closing devices for single and doubleleaf swing doors
as detailed and classified on annex 2

placed on the market under the name or trade mark of

dormakaba Deutschland GmbH

DORMA Platz 1
58256 Ennepetal
Germany

and produced in the manufacturing plant(s)

DO 2.1

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 12.07.2017 and will remain valid until 12.07.2022 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 25.10.2021



By order

Dipl.-Ing. (FH) T. Wilms
Head of Certification Body, Department 2230.2

This Certificate consists of 1 page and 1 annex(es). It replaces certificate no.
0432-CPR-00026-90 Version 01 from 12.07.2017.

The original of this document was issued in German language.

In case of doubt only the German version is valid.

Materialprüfungsamt Nordrhein-Westfalen • Marsbruchstraße 186 • 44287 Dortmund • Telefon +49 (0)231 4502-0 • Telefax +49 (0)231 458549 •

MPA NRW Brandprüfzentrum Erwitte • Auf den Thränen 2 • 59597 Erwitte • Telefon +49 (0)2943 897-0 • Telefax +49 (0)2943 897-89 •

• E-Mail: info@mpanrw.de • www.mpanrw.de •

Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

Products

type :	„TS 98 XEA“
description :	controlled door closing devices
arm system :	slide channel arm (assembly)
mounting :	Door-leaf fixing, pull side (standard installation)
	Frame fixing, pull side
	door leaf fixing, push side
size :	1-6
classification / mounting:	4 8 1-6 1 1 4
	Door-leaf fixing, pull side (standard installation)
	4 8 1-6 1 1 4
	Frame fixing, pull side
	3 8 1-6 1 1 4
	door leaf fixing, push side
manufacturing plant :	DO 2.1
hints:	with mounting plate or fire protection plate

intended use:

for single and double leaf fire- and/or smoke swingdoors

essential characteristics	clauses with requirements in EN 1154:1996/A1:2002/AC:2006	performance of product
self-closing	5.2.1 general 5.2.3 closing torque 5.2.4 opening torque 5.2.5 efficiency 5.2.6 closing time 5.2.7 opening angle door-leaf fixing, pull side frame fixing, pull side door leaf fixing, push side 5.2.8 overload test 5.2.9 temperature dependence 5.2.10 leakage 5.2.11 damage 5.2.12 latch regulation 5.2.13 back check 5.2.14 delayed action 5.2.15 adjustable force 5.2.16 free play at zero point position 5.2.18 use on fire-/smoke doors	passed passed (Size 1-6) passed (Size 1-6) passed (Size 1-6) passed (Size 1-6) passed (Class 4) passed (Class 4) passed (Class 3) passed (Size 1-6) passed passed passed passed passed passed not applicable Class 1: passed
durability self-closing	5.2.2 durability 5.2.17.1 corrosion resistance 5.2.17.2 corrosion resistance 5.2.17.3 corrosion resistance	Class 8 (500000 cycles): passed Class 4 (240h): passed Class 4 (240h): passed Class 4 (240h): passed
dangerous substances	annex ZA.3	The manufacturer has not declared any dangerous substances.

Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

Products

type :	„TS 98 XEA“
description :	controlled door closing devices
arm system :	slide channel arm (assembly)
mounting :	frame fixing, push side
Size :	1-5
classification / mounting:	4 8 1-5 1 1 4
	frame fixing, push side
manufacturing plant :	DO 2.1
hints :	with mounting plate or fire protection plate

intended use:

for single and double leaf fire- and/or smoke swingdoors:

essential characteristics	clauses with requirements in EN 1154:1996/A1:2002/AC:2006	Leistung des Produkts
self-closing	5.2.1 general 5.2.3 closing torque 5.2.4 opening torque 5.2.5 efficiency 5.2.6 closing time 5.2.7 opening angle 5.2.8 overload test 5.2.9 temperature dependence 5.2.10 leakage 5.2.11 damage 5.2.12 latch regulation 5.2.13 back check 5.2.14 delayed action 5.2.15 adjustable force 5.2.16 free play at zero point position 5.2.18 use on fire-/smoke doors	passed passed (Size 1-5) passed (Size 1-5) passed (Size 1-5) passed (Size 1-5) passed (Class 4) passed (Size 1-5) passed passed passed passed passed passed passed not applicable Class 1: passed
durability self-closing	5.2.2 durability 5.2.17.1 corrosion resistance 5.2.17.2 corrosion resistance 5.2.17.3 corrosion resistance	Class 8 (500000 cycles): passed Class 4 (240h): passed Class 4 (240h): passed Class 4 (240h): passed
dangerous substances	annex ZA.3	The manufacturer has not declared any dangerous substances.