


TECHNOTEST

DIRECTION "ASSESSMENT"

PRODUCTS CERTIFICATION BODY

Accredited by the EA "BAS", according to BDS EN ISO/IEC 17065:2012
Certificate № 4 OCPI/23.10.2018, valid until 23.10.2022



CERTIFICATE

ENGLISH EDITION

No: 41-20-D

Issued to: 07.01.2020

Valid until: 06.01.2023

CERTIFICATE HOLDER *dormakaba Bulgaria Ltd*
/PRODUCER/: *15, Heidelberg str., Druzhba 2 Distr., Sofia, 1582, Bulgaria*

With this Certificate Direction "Assessment" certifies that:

PRODUCT: *Revolving Door*

TYPE: *KTV 3 and KTV 4*

MODELS: *NS EXT; NS INT and NS EXT CH 100*

TECHNICAL DATA:

Maximum/ Minimum Dimensions: *Internal diameter (D) - 3800 mm/ 2000 mm*

*Clear passage height (PH) - 3000 mm/ 2200 mm;
Clear passage width (LW) - 2637 mm/ 940 mm.*

Drum/drum wall: *Frames and Roof Construction - Straight and curved aluminum special profiles according to the product's technical documentation.*

Night Shield, Internal and External: *Frames - Straight and curved aluminum special profiles according to the product's technical documentation. Suspension - 4 pieces of guide rollers, with retainer and limiter, on leading aluminum arches.*

Infilling: *Laminated arcuate glass with resistance class according to BDS EN 356: 2001 - P4A, or higher. Fixing in the profiles with silicone, production Kömmerling GmbH, Germany.*

Closing and Locking: *From the inside. Multi-point lock, model GU- Secury DR, production of GU GmbH, Germany. Cylinder, model pExtra production of dormakaba GmbH, Germany.*

Operation Shield: *Manual,*



Attack Side: *The outside of the door*

CONFORMS TO THE REQUIREMENTS OF: *BDS EN 1627:2011 - resistance burglary - class RC 2*

Applied scheme for certification: **B**

BASIS FOR ISSUE: *Test report No 10879/04.12.2019 according to standards BDS EN 1628:2011+A1:2016; BDS EN 1629:2011+A1:2016; BDS EN 1630:2011+A1:2016, issued by Test Laboratory of Department "Testings" - TECHNOTEST and Evaluation of Technical Documentation of the product (Dossier № 51/2019).*

The issued certificate is valid for the specific product and does not apply to its subsequent production.



Head of Direction
"Assessment"

(Ilya Hristov)