

Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

Certificate of constancy of performance**0432-CPR-00026-49**

Version 04

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Overhead door closer surface mounted TS 69

Controlled door closing devices for single and double-leaf swing doors
as detailed and classified on annex 1

placed on the market under the name or trade mark of

dormakaba Deutschland GmbH**DORMA Platz 1****58256 Ennepetal**

Germany

and produced in the manufacturing plant(s)

DO 2.5

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 01.08.2016 and will remain valid until 01.08.2026 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 19.11.2021



By order

Dipl.-Ing. (FH) T. Wilms

Head of Certification Body Department 2230.2

This Certificate consists of 1 page and 1 annex(es).
This Certificate replaces the Certificate no. 0432-CPR-00026-49 dated
12.12.2016, Version 03.

The original of this document was issued in German language.
In case of doubt only the German version is valid.



List of products

type :	„TS 69“
description :	controlled overhead door closer
arm system :	scissor arm
installation :	door leaf fixing, opening side (standard installation) frame fixing, closing side
size :	3/4
classification / installation :	size 3 4 8 3 1 1 2 door leaf fixing, opening side (standard installation) 3 8 3 1 1 2 frame fixing, closing side size 4 3 8 4 1 1 2 door leaf fixing, opening side (standard installation) 3 8 4 1 1 2 frame fixing, closing side
manufacturing plant :	DO 2.5
hints :	

intended use:

for single and double leaf fire- and/or smoke swingdoors

<i>essential characteristics</i>	<i>clauses with requirements in EN 1154:1996/A1:2002/AC:2006</i>	<i>performance of product</i>
<i>self-closing</i>	5.2.1 <i>general</i> 5.2.3 <i>closing torque</i> 5.2.4 <i>opening torque</i> 5.2.5 <i>efficiency</i> 5.2.6 <i>closing time</i> 5.2.7 <i>opening angle</i> size 3 door leaf fixing, opening side frame fixing, closing side size 4 door leaf fixing, opening side frame fixing, closing side 5.2.8 <i>overload test</i> 5.2.9 <i>temperature dependence</i> 5.2.10 <i>leakage</i> 5.2.11 <i>damage</i> 5.2.12 <i>latch regulation</i> 5.2.13 <i>back check</i> 5.2.14 <i>delayed action</i> 5.2.15 <i>adjustable force</i> 5.2.16 <i>free play at zero point position</i> 5.2.18 <i>use on fire-/smoke doors</i>	<i>passed</i> <i>passed (size 3/4)</i> <i>passed (size 3/4)</i> <i>passed (size 3/4)</i> <i>passed (size 3/4)</i> <i>class 4: passed</i> <i>class 3: passed</i> <i>class 3: passed</i> <i>class 3: passed</i> <i>passed (size 3/4)</i> <i>passed (size 3/4)</i> <i>passed (size 3/4)</i> <i>passed (size 3/4)</i> <i>passed (size 3/4)</i> <i>not applicable</i> <i>not applicable</i> <i>not applicable</i> <i>not applicable</i> <i>class 1: passed</i>
<i>durability self-closing</i>	5.2.2 <i>durability</i> 5.2.17.1 <i>corrosion resistance</i> 5.2.17.2 <i>corrosion resistance</i> 5.2.17.3 <i>corrosion resistance</i>	<i>class 8 (500 000 cycles): passed</i> <i>class 2 (48h): passed</i> <i>class 2 (48h): passed</i> <i>class 2 (48h): passed</i>
<i>dangerous substances</i>	<i>annex ZA.3</i>	<i>The manufacturer has not declared any dangerous substances</i>